

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1483:177

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models CSB4U-1 and CRB4U-1 smoke detector bases. Bases are for use with the Models MC10U-3, MC30U-3, smoke detector heads and Models MC20FTU-3 and MC20RRU-3 heat detector heads. Model CSB4U-1 is a 2-wire relay base with dry contacts for external connections. Model CRB4U-1 is a basic 2-wire base with no electronics employed. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as detector bases for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

FORMERLY: 7300-1591:235

XL: **7300-1657:235**

09-08-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

